PARTS LIST SL. NO. QTY. DESCRIPTION MODEL BRAND 1 2 BEVELED SWING CLEAR PIN & BARREL CONTINUOUS 711BSC	5/8	2	5/8 — 2 — 1
2 2 INSET CVR EXIT DEVICE WITH LBR OPTION X TRIM 94/9547 (LBR) (PUSH SIDE) X 940 L-BE (PULL SIDE) VON DUPRIN 3 2 WALL MOUNTED TRACK ARM CLOSER 4000T 4 2 MAGNETIC DOOR HOLDER SEM 7850	- 9 / 32	7/16	7/16
5 2 DOORS (ADD ADA LIGHT IN CROSS CORRIDOR HEALTHCARE APPLICATIONS) LI8 HC CORE 6 I FRAME STEELCRAFT STEELCRAFT			
7 2 PERIMETER & MEETING EDGE GASKETING (N/A FROM STL) 488/188 & 328 ZERO, OTHERS NOTES:			
I. MAX 8'0" (96") NOMINAL OPENING WIDTH (SHOWN). DOORS ARE DOWNSIZED FOR TYP 3/32" GAPS AT BEVELED DOOR EDGES, AND FOR HINGES.	3 - 5 / 8	7-1/8 NOMINAL J DEPTH (ACTUAL 7-	-5/32 DEPTH (ACTUAL 7-5/32
2. FORMULA FOR CLEAR OPENING: FOR ANY NOMINAL OPENING WIDTH "N", THE U.S. ADA CLEAR OPENING WIDTH IS 47-5/16 - (96 - N) / 2, AND THE CBC OPENING WIDTH IS 45-11/16 - (96 - N) / 2. CA CBC EXAMPLE: IF A = 6'0", OR 72", THEN 45-11/16 - (96 - 72) / 2 = 33-11/16 CLEAR.		VARIES WITH MATERIAL GAUGE	
3. ORDER CLOSERS USING ONE OF THE FOLLOWING OPTIONS: - PI-90-3T FOR 4003T (34"-42" WIDTH) STD TEMPLATE PI-90-4T FOR 4004T (>42"-48" WIDTH) STD TEMPLATE.	- 3 / 3 2		1-31/32
- PI-90-ADA FOR 4003T X ST-2967. ST-2967 SHIPS STD 4040XP CYLINDER; SPRING SETTING MUST BE FIELD ADJUSTED TO CLOSE THE DOOR. - MAY SUBSTITUTE (REF NOTE 5) 4000T WALL MOUNTED CLOSER WITH 4040XP DOOR MOUNTED CLOSER AND STD Rw/PA TEMPLATE.	<u></u>		
4. MIN 12 GAUGE STEEL BACKER (BY OTHERS) FOR MOUNTING CLOSER TO WALL. EXTEND BACKER PAST SIZE OF CLOSER TO SUPPORT MINOR VARIANCES IN CLOSER LOCATION AND DISTANCE TO MOUNTING SCREWS.		JAMB DETAIL	5/8 - 2 HEAD DETAIL
5. DIMENSIONAL AND CALCULATED VALUES MAY VARY DEPENDING ON ALLOWABLE MANUFACTURING TOLERANCES AS WELL AS DIFFERENCES IN YOUR OPENING SUCH AS WALL THICKNESS, FRAME AND ANCHOR TYPE SUBSTITUTE HARDWARE MAY BE USED IF AVAILABLE WITH THIS SYSTEM; CHANGES MAY AFFECT WALLS, DOOR DOWNSIZING AND CLEAR OPENING.			
SODSTITUTE HANDWARE MAT DE OSED IT AVAILADEL WITH THIS STOTEM, CHANOLS MAT ATTECT WALLS, DOOR DOWNSTZING AND CLEAR OTENTION.			
4			
3-5/8 300R 47-5/8		-JUNCTION BOX	
(45-31/32)			
U.S. ADA 404.2.3 DOOR FACE TO OPPOSITE DOOR EDGE) SEE NOTE 2		2 - 3 / 3 2	
MUST MEET NFPA80 (1/8" ± 1/16") AND ADA CLEAR OPENING REQUIREMENTS.		SEE NOTE 4	
NOMINAL OPENING WIDTH		(6-7/32)	
(2) 5/8" SHEETS OF WA BOARD SHOWN WITH I/ PENETRATION IN FRAME(REFERENCE NEPA	2"	U INPAC By Pair Ap COPYRIGH	RATED DOOR SYSTEM (711BSC Hinge) Oplication (same swing) HT © 2022 SCHLAGE LOCK CO LLC S RESERVED v.7/27/2022









